

Ogaki-Kita Plant

<Total Wastewater Measurement>

Item	Unit	National standard	City standard	Voluntary standard	Average	Maximum	Note
pH	-	5.8～8.6	5.8～8.6	6.0～8.3	7.7	7.9	
BOD	mg / L	160	30	20	1.9	4.3	
COD	mg / L	160	Regulation of total emission	Regulation of total emission	4.8	10.0	
SS	mg / L	200	30	25	1.6	10.0	
Copper	mg / L	3	2	1	0.02	0.07	
Fluorine and fluorine compounds	mg / L	8	8	8	0.1	0.1	
Phenol	mg / L	5	0.4	0.4	0.1	0.1	
n-H mineral oils	mg / L	5	5	4	1	1	
Nitrogen	mg / L	120	60	50	6.7	16.0	
Phosphorus	mg / L	16	8	7	1.0	1.9	
Boron and boron compounds	mg / L	10	10	10	0.1	0.1	
Ammonia and ammonium compounds,nitrite and nitrate compounds	mg / L	100	100	100	4.0	8.0	

<Air Measurement>

Item	Equipment	Unit	National standard	City standard	Voluntary standard	Average	Maximum	Note
Hydrogen sulfide	Vacuum incinerator	ppm	0.02	0.02	0.02	<0.0005	<0.0005	

<Noise Measurement>

Place	Unit	National standard	City standard	Voluntary standard	Average	Maximum	Note
North (morning・evening)	dB	60	60	60	40	68	The noise level from insect sounds exceeded the standard.
East (morning・evening)	dB	60	60	60	44	64	The noise level from insect sounds exceeded the standard.
South (morning・evening)	dB	60	60	60	42	61	The noise level from insect sounds exceeded the standard.
Western angle of Building D (morning・evening)	dB	60	60	60	40	64	The noise level from insect sounds exceeded the standard.
West (morning・evening)	dB	60	60	60	46	65	The noise level from insect sounds exceeded the standard.
Graveyard (morning・evening)	dB	60	60	60	41	63	The noise level from insect sounds exceeded the standard.
Graveyard West (morning・evening)	dB	50	50	50	39	59	The noise level from insect sounds exceeded the standard.
North (night)	dB	50	50	50	37	54	The noise level from insect sounds exceeded the standard.
East (night)	dB	50	50	50	42	47	
South (night)	dB	50	50	50	40	47	
Western angle of Building D (night)	dB	50	50	50	37	57	The noise level from insect sounds exceeded the standard.
West (night)	dB	50	50	50	43	50	The noise level from insect sounds exceeded the standard.
Graveyard (night)	dB	50	50	50	38	54	The noise level from insect sounds exceeded the standard.
Graveyard West (night)	dB	45	45	45	37	47	The noise level from insect sounds exceeded the standard.

Kinuura Plant

< Wastewater Measurement >

Item	Unit	National standard	City standard	Voluntary standard	Average	Maximum	Note
pH	-	5.8~8.6		6.0~8.4	7.5	7.7	
BOD	mg / L	160		20	6.8	15	
COD	mg / L	160	160	30	8.8	10	
SS	mg / L	200		20	3.8	9	
Copper	mg / L	3		0.2	0.01	0.01	
Fluorine and fluorine compounds	mg / L	8		3	0.1	0.1	
Phenol	mg / L	5		0.2	0.1	0.1	
n-H mineral oils	mg / L	5		1	1	1	
Nitrogen	mg / L	120	120	30	11	11	
Phosphorus	mg / L	16	16	3	0.58	0.58	
Soluble manganese	mg / L	10		3	0.19	0.19	
Zinc	mg / L	2		1	0.02	0.02	
Solubility iron	mg / L	10		3	0.8	0.8	
Total chromium	mg / L	2		1	0.02	0.02	
Coliform bacilli	個 / cm ³	3,000		1,000	<1	<1	
Boron and boron compounds	mg / L	10		3	0.1	0.1	
Ammonia and ammonium compounds, nitrite and nitrate compounds	mg / L	100		50	8	8	

< Air Measurement >

Item	Equipment	Unit	National standard	City standard	Voluntary standard	Average	Maximum	Note
Soot	Once-through boiler No.6	g/m ³ N	0.1		0.1	0.001	0.001	
	Once-through boiler No.7	g/m ³ N	0.1		0.1	0.001	0.001	
	Once-through boiler No.8	g/m ³ N	0.1		0.1	0.001	0.001	
	Once-through boiler No.9	g/m ³ N	0.1		0.1	0.001	0.001	
NOx	Once-through boiler No.6	ppm	150		150	41	41	
	Once-through boiler No.7	ppm	150		150	41	39	
	Once-through boiler No.8	ppm	150		150	36	36	
	Once-through boiler No.9	ppm	150		150	38	38	

< Noise Measurement >

Place	Unit	National standard	City standard	Voluntary standard	Average	Maximum	Note
Main gate (daytime)	dB	75		75	53	56	

Godo Plant

<Wastewater Measurement - West>

Item	Unit	National standard	City standard	Voluntary standard	Average	Maximum	Note
pH	-	5.8～8.6	5.8～8.6	5.8～8.6	7.6	8.0	

<Wastewater Measurement - East>

Item	Unit	National standard	City standard	Voluntary standard	Average	Maximum	Note
pH	-	5.8～8.6	5.8～8.6	5.8～8.6	7.8	8.2	

<Noise Measurement>

Place	Unit	National standard	City standard	Voluntary standard	Average	Maximum	Note
East (morning・evening)	dB	65	65	65	46	51	
West (morning・evening)	dB	65	65	65	46	52	
South (morning・evening)	dB	65	65	65	44	48	
North (morning・evening)	dB	65	65	65	46	51	
East (night)	dB	60	60	60	44	48	
West (night)	dB	60	60	60	44	48	
South (night)	dB	60	60	60	43	47	
North (night)	dB	60	60	60	45	51	